

Accredited for compliance with ISO/IEC 17025-Testing.
Accreditation No. 20148, Site No. 24777 Melbourne Laboratory, 24010
Darwin Laboratory & 25528 Adelaide Laboratory.
The results relate only to the samples tested and are for the sole use by the client.



This document shall not be reproduced, except in full.

## **ASBESTOS IDENTIFICATION RESULTS**

.. Hongtai Integrated Housing Technology

Agon Job No:

JH25.0326-49

Applicant: (Suzhou) Co., Ltd

Date:

10 September 2025

Address: No. 6, Tianliangqiao Road, Zhenze Town,

Received Date:

9 September 2025

Wujiang District, Suzhou City, Jiangsu Province

Sampled By:

As received

**Product Name:** Color Steel Rock Wool Sandwich Panel

Agon Lab Site:

Adelaide, Australia

Test Method:

Qualitative Identification of asbestos samples under polarising light microscopy including dispersion staining and trace analysis with a calculated practical detection limit of 0.01% using methodology as per Australian Standard AS4964 (2004) and inhouse

Laboratory Procedure LP-004 Asbestos Identification Manual

Client ID	Lab Description	Asbestos Detected	Analysis Result
Color Steel Rock Wool Sandwich Panel	Green fibrous layer sandwiched by a painted metal sheet The sample submitted weighed 20g	No	No asbestos detected <sup>{S}</sup>

<sup>&</sup>lt;sup>5</sup> Synthetic Mineral Fibre (commonly known as glass fibre) detected in the reinforcing mesh – note that this is not asbestos, but is included in the report to satisfy NATA reporting requirements

## Michael Till

Approved Identifier / Signatory

Any and all services carried out by Agon for the Client are subject to the Terms and Conditions provided in Agon form QFB-008 and are governed by our Statement of Limitations provided in Agon form QFB-024 (both documents accessible at <a href="https://agonenviro.com.au/documents/">https://agonenviro.com.au/documents/</a>

m J Till

