

ASBESTOS IDENTIFICATION RESULTS

Applicant:	Hongtai Integrated Housing Technology (Suzhou) Co., Ltd	Agon Job No:	JH25.0326-49
Address:	No. 6, Tianliangqiao Road, Zhenze Town, Wujiang District, Suzhou City, Jiangsu Province	Date:	10 September 2025
Product Name:	Glass Fiber and Magnesium Cement Board	Received Date:	9 September 2025
Test Method:	Qualitative Identification of asbestos samples under polarising light microscopy including dispersion staining and trace analysis with a calculated practical detection limit of 0.01% using methodology as per Australian Standard AS4964 (2004) and inhouse Laboratory Procedure LP-004 Asbestos Identification Manual		
		Sampled By:	As received
		Agon Lab Site:	Adelaide, Australia

Client ID	Lab Description	Asbestos Detected	Analysis Result
Glass Fiber and Magnesium Cement Board	Grey board with a reinforcing mesh on both sides The sample submitted weighed 50g	No	No asbestos detected ^{S, O}

^S Synthetic Mineral Fibre (commonly known as glass fibre) detected in the reinforcing mesh – note that this is not asbestos, but is included in the report to satisfy NATA reporting requirements

^O Organic Fibre detected in the reinforcing mesh – note that this is not asbestos, but is included in the report to satisfy NATA reporting requirements

Michael Till

Approved Identifier / Signatory



Any and all services carried out by Agon for the Client are subject to the Terms and Conditions provided in Agon form QFB-008 and are governed by our Statement of Limitations provided in Agon form QFB-024 (both documents accessible at <https://agonenviro.com.au/documents/>)



Melbourne Laboratory - H76, 63-85 Turner Street, Port Melbourne, 3207 | Darwin Laboratory - 1/41 Jessop Crescent, Berrimah, NT 0828 |

Adelaide Laboratory - 3/224 Glen Osmond Road, Fullarton, SA 5063

Agon Environmental Pty Ltd A.B.N. 29 167 746 063

+61 8 8166 2410

www.agonenviro.com.au